

## TECHNICAL SPECIFICATION

### **TECHNICAL SPECIFICATION FOR 12 KV STATION CLASS LIGHTNING ARRESTORS**

#### **1. SCOPE :**

This Specification covers design, manufacture, testing at manufacturer's Works, packing, supply, delivery of 12 KV classes of gapless Lightning Arrestors complete with fittings and accessories.

These arrestors shall be of Heavy Duty, Station Class and Gapless Zinc Oxide type.

Arrestors shall be hermetically sealed units suitable for outdoor installation on self-supporting base or structures.

#### **2. STANDARD :**

Arrestors shall conform in general to IEC-99-4 document or its latest amendment and IS/IEC as follows:

- i) IEC-99-4 : Gapless Lightning Arrestor
- ii) IS 3070 P-III : Metal Oxide Surge Arrestors without gaps for AC Systems.
- iii) IEC 99 P-III : Artificial Pollution Testing of Lightning Arrestor
- iv) IEC 270 : Partial Discharge Measurement.
- v) IS 2071 : Methods of H V Testing
- vi) IS 6209 : Methods for Partial Discharge Measurement
- vii) IS 5621 : Hollow Insulators for use in electrical equipment

#### **3. DEVIATION :**

Normally the offer should be as per Technical Specification without any deviation. But any deviation felt necessary to improve performance, efficiency and utility of equipment must be mentioned in the 'Deviation Schedule' with reasons duly supported by documentary evidences and advantages of such deviation. Such deviations suggested may or may not be accepted. But deviations not mentioned in Deviation Schedule will not be considered.

#### **4. DUTY REQUIREMENT :**

The Surge Arrestors are being provided to protect the following equipment whose insulation levels are indicated in the table given below:

| Equipment to be protected   | L I for 12 KV system KVp) |
|-----------------------------|---------------------------|
| Power Transformer           | ±75                       |
| Instrument Transformer      | ±75                       |
| CB/Isolator Phase to ground | ±75                       |
| Across open poles           | -                         |

The Lightning Arrestors shall be capable of discharging Lightning and switching surges and temporary power frequency over voltages. The Surge Arrestor shall be capable of discharging over voltages occurring during switching of unloaded transformers and long lines.

The Arrestors shall be capable of withstanding Maximum Continuous Operating Voltages (M.C.O.V.).

S. Chatterjee 14/9/21

S. Chatterjee 14/9/21

14/9/21

14/9/21

14/9/21

14/9/21

The reference current of the Arrestors shall be high enough to eliminate the influence of grading and stray capacitance on the measured reference voltages.

Arrestor shall be directly mounted on structure as there is no surge counter.

- i) Name of device
- ii) Manufacturer's name and trade mark, type and identification
- iii) Year of manufacture
- iv) Voltage rating & frequency rating.
- v) Nominal discharge current
- vi) MCOV (Maximum Continuous Operating Voltage in KV).
- vii) Discharge class.
- viii) Energy Discharge capability (KJ/KV rating)
- ix) Purchase Order reference.
- x) Applicable Standard.
- xi) Pressure Relief rated current in KA rms
- xii) Serial Number
- xiii) Property Plate ("Property of WBS&EDCL")

Two ground terminal connectors suitable for G.I strip of required size shall be provided on diagonally opposite sides.

5.9 12 KV Lightning Arrestor should be of **station class type** and should have suitable **Fault Indicator**.

The arrester elements shall be designed in such a way as to obtain robust construction with excellent mechanical and electrical properties even after repeated operation. The lightning arrestors should be adequately designed to operate satisfactorily under temporary power frequency over voltage as given in Specific Technical Parameters, after discharging two shots of respective long duration surges. Uniform density of zinc oxide element shall be maintained to provide uniform current distribution.

Sufficient creepage distance shall be provided to reduce excessive uneven voltages over the porcelain due to contamination, for which the arrester shall not fail.

Housing of Insulators shall be of **Porcelain**, glazed and completely vitrified and free from blow holes, micro-cracks or void. **Porcelain**, housing shall be so coordinated that external flashover will not occur due to application of any impulse or switching surge voltage up to the maximum design value for the arrester.

Housing of Insulators shall be of **Porcelain**, glazed and completely vitrified and free from blow holes, micro-cracks or void. **Porcelain**, housing shall be so coordinated that external flashover will not occur due to application of any impulse or switching surge voltage up to the maximum design value for the arrester.



## 7 APPLICATION :

## 8 TENDER DRAWINGS, CATALOGUES:

## 9 CONTRACT DRAWINGS AND MANUALS :

## 10 TEST REPORTS AND TYPE TESTS :

**11 TEST AT FACTORY AND TEST CERTIFICATES :**

- IEC:99-4 & IS:3070 (Part - III).

12. TYPE TESTS after issuance of order :

However the necessary cost of the Type Test charges will be reimbursed to the party on production of necessary supporting documents.

- a) Copy of Purchase Order.
- b) Copy of Despatch Instruction.
- c) Inspection Test Certificate.
- d) Guarantee Certificate.
- e) Proforma Invoice.
- f) Calculation Sheet for price Variation on the basis of IEEMA or CACMAI as applicable with base date of order.
- g) Seal list and packing list.
- h) Challan in triplicate.
- i) Way bill, if applicable.



### SPECIFIC TECHNICAL PARAMETERS- I

| TYPE OF ARRESTOR   |  | STATION CLASS<br>HEAVY DUTY GAPLESS        |
|--|--|--|
| i)   | Nominal system voltage (KV)  | 11   |
| ii)  | Highest system voltage (KV)  | 12   |
| iii)   | System Neutral Earthing  | Effectively Earthed                        |
| iv)  | BIL of transformers (KVp)  | 75   |
| v)   | System fault level (KA)  | 18.4                                       |
| vi)  | Maxm. System BIL (KVp)   | 75   |
| <b><u>LA RATINGS :</u></b>   |  |  |
| i)   | Rated Voltage (KV)   | 12   |
| ii)  | Maxm. Continuous operating voltage (KVRms)   | 10   |
| iii)   | Nominal Discharge Current (KA <sub>p</sub> )   | 10   |
| iv)  | Line discharge class   | 2  |
| v)   | Minimum Energy Discharge capability (KJ/KV)  | >2   |
| [If there is any Deviation the same may be mentioned in the Deviation Sheet] |  |  |
| vi)  | Temporary over voltage withstand capability (KVRms) for 10.0 secs  | 12   |
| vii)   | Insulation Housing withstand voltages<br>i) Lightning Impulse(Dry)<br>ii) Power frequency(wet)<br>for 10 KA                      | Minimum values as per IEC                  |
| viii)  | Minimum creepage Distance acceptable (mm)  | 300  |
| i) Pressure Relief Class   |  | To be tested in accordance with IEC        |
| ix)  | (Minimum) High Current Impulse withstand (4/10) KA (peak)  | 100  |
| x)   | Maxm.Lightning Impulse (8/20 micro-second impulse) residual voltage (KVp) :  |  |
|  | 5 KA   |  |
|  | 10KA   | 40   |
| xi)  | Maxm. switching surge (30/60 micro-second wave) protective level (KVp)   |  |
|  | 500 Amps   | 21   |
|  | 1000 Amps  | -  |
|  | 2000 Amps  | -  |
| xii)   | Maxm. Steep Impulse (1/20 micro-seconds impulse) residual voltage at 10 KA (KVp)   | 45   |
| xiii)  | RIV/Partial Discharge (micro-volt / pico-coulomb) when energised at 1.05 times its continuous operating voltage shall not exceed | 1000 microvolt/ less than 500 pico-coulomb |
| xiv)   | Terminal connection  | Suitable for Dog/Rabbit ACSR Conductor     |
| xv)  | Rated Frequency (Hz)   | 50   |
| xvi)   | Minimum Visible Corona Discharge voltage(KV rms)   | -  |

12 }  
 13 }  
 14 }  
 15 }  
 16 }  
 17 }  
 18 }  
 19 }  
 20 }  
 21 }  
 22 }  
 23 }  
 24 }  
 25 }  
 26 }  
 27 }  
 28 }  
 29 }  
 30 }  
 31 }  
 32 }  
 33 }  
 34 }  
 35 }  
 36 }  
 37 }  
 38 }  
 39 }  
 40 }  
 41 }  
 42 }  
 43 }  
 44 }  
 45 }  
 46 }  
 47 }  
 48 }  
 49 }  
 50 }  
 51 }  
 52 }  
 53 }  
 54 }  
 55 }  
 56 }  
 57 }  
 58 }  
 59 }  
 60 }  
 61 }  
 62 }  
 63 }  
 64 }  
 65 }  
 66 }  
 67 }  
 68 }  
 69 }  
 70 }  
 71 }  
 72 }  
 73 }  
 74 }  
 75 }  
 76 }  
 77 }  
 78 }  
 79 }  
 80 }  
 81 }  
 82 }  
 83 }  
 84 }  
 85 }  
 86 }  
 87 }  
 88 }  
 89 }  
 90 }  
 91 }  
 92 }  
 93 }  
 94 }  
 95 }  
 96 }  
 97 }  
 98 }  
 99 }  
 100 }

## GUARANTEED TECHNICAL PARAMETERS

| <u>TYPE OF ARRESTOR</u> |  | <u>STATION CLASS</u><br><u>HEAVY DUTY GAPLESS</u><br><u>(12KV)</u> |
|-------------------------|--|--|
| i)                      | Nominal system voltage (KV)  |  |
| ii)                     | Highest system voltage (KV)  |  |
| iii)                    | System Neutral Earthing  |  |
| iv)                     | BIL of transformers (KVp)  |  |
| v)                      | System fault level (KA)  |  |
| vi)                     | Maxm. System BIL (KVp)   |  |
| <b>LA RATINGS :</b>     |  |  |
| i)                      | Rated Voltage (KV)   |  |
| ii)                     | Maxm. Continuous operating voltage (KVrms)   |  |
| iii)                    | Nominal Discharge Current (KAp)  |  |
| iv)                     | Line discharge class   |  |
| v)                      | Minimum Energy Discharge capability (KJ/KV)  |  |
|                         | [If there is any Deviation the same may be mentioned in the Deviation Sheet]   |  |
| vi)                     | Temporary over voltage withstand capability (KVrms) for 10.0 secs  |  |
| vii)                    | Insulation Housing withstand voltages  |  |
|                         | i) Lightning Impulse(Dry)  |  |
|                         | ii) Power frequency(wet)   |  |
|                         | for 10 KA  |  |
| viii)                   | Minimum creepage Distance acceptable (mm)  |  |
|                         | i) Pressure Relief Class   |  |
| ix)                     | (Minimum) High Current Impulse withstand (4/10) KA (peak)  |  |
| x)                      | Maxm. Lightning Impulse (8/20 micro-second impulse) residual voltage (KVp) :   |  |
|                         | 5 KA   |  |
|                         | 10KA   |  |
| xi)                     | Maxm. switching surge (30/60 micro-second wave) protective level (KVp)   |  |
|                         | 500 Amps   |  |
|                         | 1000 Amps  |  |
|                         | 2000 Amps  |  |
| xii)                    | Maxm. Steep Impulse (1/20 micro-seconds impulse) residual voltage at 10 KA (KVp)   |  |
| xiii)                   | RIV/Partial Discharge (micro-volt / pico-coulomb) when energised at 1.05 times its continuous operating voltage shall not exceed |  |
| xiv)                    | Terminal connection  |  |
| xv)                     | Rated Frequency (Hz)   |  |
| xvi)                    | Minimum Visible Corona Discharge voltage(KV rms)   |  |

Date:

Signature:

Place:

Name:

Name of the Company:

Seal of the Company:

14/9/21

Green

14/9/21

14/9/21

14/9/21

14/9/21

14/9/21

14/9/21

14/9/21

14/9/21

14/9/21

14/9/21

14/9/21

14/9/21